

# OFFICE OF THE MUNICIPAL COMMITTEE AKHNOOR

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. MCA/2024/799

Dated: 09-12-2024

It is certified that an inspection team headed by J/c Sanitation Section  
(Name of Officers with designation) from Sh. Kuldeep Kumar (J/c Sanitation Section)  
(Name of Department/ Office) inspected the Municipal Committee Akhnoor.  
(Name & Address of the school) on 07/12/2024 (date of inspection) and found that the Shubh International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of one year.

Signature with Seal: [Signature]  
Name: Executive Officer  
Designation: Municipal Committee Akhnoor

Name & Address of the Office / Department: Municipal Committee Akhnoor.

To

Principal  
Shubh International School  
Akhnoor,  
(Name & Address of the Institution)



**JAL SHAKTI (PHE) DEPARTMENT DIVISION AKHNOOR**  
**WATER TESTING LABORATORY AKHNOOR**  
**PINCODE : 181201**



**Test Report**

Report No:	2295 (Chemical & Bacteria)	Report Date:	05-Dec-2024	
Source:	Bore-Well			
Test Condition:	SAFE / UNSAFE			
Location:	SHUBH INTERNATIONAL SCHOOL AKHNOOR			
Sr. No	Parameter	BIS Permissible limit(mg/l)	BIS Desirable limit(mg/l)	Test Results (mg/l)
1	Turbidity	5.00 (NTU)	1 (NTU)	1.88 N.T.U.
2	pH	8.5	6.5	7.02 pH
3	TDS	2000	500	341 mg/l
4	Fluoride	1.5	1.0	0.5 mg/l
5	Nitrate	45	45	01 mg/l
6	Calcium	200	75	135 mg/l
7	Total Hardness	600	200	320 mg/l
8	Iron	1.0	0.3	0.4 mg/l
9	Residual Free Chlorine	1.0 (At Source)	0.2	0.0 mg/l
<b>Bacteriological Quality Parameter</b>				
10	E-Coli	Absent/100 ml	Absent/100 ml	Absent/100 ml

**Note:**

- The test report and result relate to the specimen/ sample (s) of the material as delivered /received and tested in the laboratory.
- This test report shall not be reproduced in part, without the permission of this laboratory.
- Any correction invalidates this test reports.
- WQC lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/legal liability arising out of any errors or omissions. Refer to terms & Conditions of reports overleaf.

*[Signature]*  
Laboratory Incharge  
Water Quality Control  
Jal Shakti (PHE) Dept.  
Jal Shakti Division, Akhnoor.

**ASSISTANT EXECUTIVE ENGINEER**  
Water Quality Control  
Jal Shakti (PHE) Dept.

*[Signature]*  
Assistant Executive Engineer  
Jal Shakti (PHE) Sub Division  
Akhnoor (Civil)